

Veterans Home of CA-Chula Vista  
700 E. Naples Ct.  
Chula Vista, CA 91911

**Fire Safety Correction for the following Deficiencies:**  
**File #: 01-27-11-0048**

<b>Deficiency</b>	<b>Corrective Action</b>
<b>Service label on riser. Title 19, 906</b>	Aztec Fire and Safety was contacted by Plant Operation Staff on 9/22/08 to have service label changed to a stamped metal label instead of current paper label, which were installed during original construction. Two of three competitive bidding quotes have been obtained. The new riser label will be purchased and installed by 11/17/08.
<b>Circuit breaker blank spaces. CEC 370-18</b>	The blank space in the circuit breaker was repaired on 9/23/08.
<b>Required space around electrical panels (36"). CEC 110-26</b>	All laundry carts around the electrical panel in the clean laundry area have been rearranged so the required 36" of space is established and maintained at all times. The Procurement Officer has instructed staff to maintain required space and will make regular rounds to ensure compliance with this regulation.
<b>No storage permitted in boiler room, mechanical room, electrical equipment room. T19, 3.19f</b>	All storage materials were removed from the boiler room, mechanical room and electrical equipment rooms on 9/23/08 and 9/24/08.
<b>General housekeeping of occupancy (trash, flammables). Title 19, 3.19</b>	All boxes that were stored under the desks in the Dietary Office were immediately removed. The Dietary Supervisor will make regular rounds to ensure compliance.
<b>Exit path obstructed. CBC 1001.1</b>	The door that was blocked is not an exit or entrance. A temporary sign has been placed on the exterior of the door indicating, "This door is blocked." A permanent sign has been ordered and will be installed by 11/17/08.